

Certificate

No. 58 261

Applicant: **SCHMITZ -Werke GmbH + Co. KG**
Hansestraße 87
D-48282 EMSDETTEN
DEUTSCHLAND

Date of application: 2008-08-14

Denomination: **"drapilux-flammstop-Kollektion"**


Description of the sample: Drapes and curtains


This document confirms that the above named drape/curtain **"drapilux-flammstop-Kollektion"** was classified in this laboratory with test report number 58 261 of 9th June 2008. The burning behaviour was classified after one cleaning procedure according EN 13772, no burning and no propagation of flames was determined.

The drape/curtain **"drapilux-flammstop-Kollektion"** can be classified as

Class 1 according EN 13 773

Vienna, 2008-08-20


Responsible for Testing
Ing. Hanspeter Bauer


Director
Dipl.-Ing. Dr. Erich Zippel